


Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,
An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

DESERT SPRINGS BOTTLED WATER
“Product”

on January 20, 2019, according to the FDA testing requirements for bottled drinking water.
All parameters were found to be in compliance with 21 CFR 165 and 21 CFR 129
published limits for bottled drinking water.



Lawrence J. Henderson, PhD
Director of Laboratories

The signature of Lawrence J. Henderson, PhD, is written in black ink above a horizontal line. Below the line, his name and title are printed in a blue, sans-serif font.

18-45586



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

January 18, 2019

Page 1 of 1

Tammie Williams
Desert Springs Bottled Water
PO BOX 273
Echo, OR 97826

RE: 18-45586 - FDA Annual - Product

Dear Tammie Williams,

Your project: FDA Annual - Product, was received on Friday December 07, 2018.

All samples were analyzed within the accepted holding times and were appropriately preserved and analyzed according to approved analytical protocols, unless noted in the data or QC reports. The quality control data was within laboratory acceptance limits, unless specified in the data or QC reports.

If you have questions phone us at 800 755-9295.

Respectfully

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Enclosures: Data Report
QC Reports
Chain of Custody



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Desert Springs Bottled Water
 PO BOX 273
 Echo, OR 97826

Reference Number: **18-45586**
 Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Project: FDA Annual - Product
 Field ID: FDA Annual

Sample Description: Product
 Sampled By:
 Sample Date: 12/11/2018

Lab Number: 92943
 Report Date: 01/18/2019
 Approved By: anp,bj,dst,fn,hkl,hy,pdm

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	ND	1.0	0.010	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	ND	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE/NITRITE	ND	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:
 A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	ND	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.010	mg/L	200.8	a	
14808-79-8	SULFATE	ND	250	0.2	mg/L	300.0	a	
57-12-5	CYANIDE	ND	0.2	0.010	mg/L	OIA-1677-DW	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	ND	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.00	0.050	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.4	ug/L	524.2	a	
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.4	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.4	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	a	
75-09-2	METHYLENE CHLORIDE (DICHLOROMETHANE)	ND	3	0.4	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	5	0.4	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	a	
E-14471	TOTAL TRIHALOMETHANE	ND	80	0.4	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.02	ug/L	504.1	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB)	ND	0.5	0.5	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
103-23-1	DI(ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
E-10253	TOTAL RECOVERABLE PHENOLICS	ND	1	1	ug/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-10139	HYDROGEN ION (pH)	5.96			pH Units	150.1	a	Temp (C) : 20.2
E-11712	COLOR	ND	15	5	COLOR UI	SM2120 B	a	pH: 5.96
E-11734	ODOR	ND	3	1	TON	SM2150	a	Temperature: 40.8
E-10617	TURBIDITY	ND	1	0.10	NTU	180.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
NA	HAA(5)	ND	60	0	ug/L	552.3	a	
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
10049-04-4	CHLORINE DIOXIDE	ND		0.10	mg/L	SM4500-CIO2 I	a	
7758-19-2	CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
	CHLORAMINES TOTAL	ND	4.0	0.05	mg/L	SM4500-CI G	a	
7782-50-5	FREE CHLORINE RESIDUAL	ND	0.1	0.05	mg/L	SM4500-CI G	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	3	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50	4	pCi/L	900.0		Analyzed by Pace
13982-63-3	RADIUM 226	ND		1	pCi/L	903.1		Analyzed by Pace
15262-20-1	RADIUM 228	ND	5	1	pCi/L	904.0		Analyzed by Pace
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Data Report

Client Name: Desert Springs Bottled Water
 PO BOX 273
 Echo, OR 97826

Reference Number: **18-45586**
 Project: FDA Annual - Product

Report Date: 1/18/19

Date Received: 12/7/18

Approved by: anp,bj

Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Sample Description: FDA Annual - Product										Sample Date: 12/11/18 10:06 am		
Lab Number: 92943		Sample Comment:							Collected By:			
CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	ND	0.5	0.009	mg/L	1.0	200.7	a	12/17/18	ANP	200.7_181217A	
E-11778	HARDNESS as Calcium Carbonate	ND	3.3	0.01	mg/L	1.0	200.7	a	12/17/18	ANP	200.7_181217A	
7439-95-4	MAGNESIUM	ND	0.5	0.001	mg/L	1.0	200.7	a	12/17/18	ANP	200.7_181217A	
7440-09-7	POTASSIUM	ND	1.0	0.1	mg/L	1.0	200.7	a	12/17/18	ANP	200.7_181217A	
7440-23-5	SODIUM	ND	0.5	0.05	mg/L	1.0	200.7	a	12/17/18	ANP	200.7_181217A	
E-10184	ELECTRICAL CONDUCTIVITY	ND	10		uS/cm	1.0	SM2510 B	a	12/11/18	HKL	ec_181211	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
 D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.