



Burlington, WA Corporate Laboratory (a)  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA Microbiology (b)  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR Microbiology/Chemistry (d)  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR Microbiology (e)  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Idaho Ice  
 220 W. Morton St.  
 Moscow, ID 83843

Reference Number: **19-42493**

Authorized by:

  
 Patrick Miller, MS  
 QA Officer

Project: 50 State Source Testing

Field ID:

Sample Description: Source

Sampled By: Jim Schwartz

Sample Date: 11/05/2019

Lab Number: 82175

Report Date: 01/06/2020

Approved By: ajw,bj,bsp,fm,hjb,hy,ljh,mle,

### Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
57-12-5	CYANIDE	ND	0.2	0.01	mg/L	OIA-1677-DW	a	
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	<b>0.0236</b>	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.001	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	ND	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE/NITRITE	ND	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

If you have any questions concerning this report contact us at the above phone number.

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	0.4	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	0.0094	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.001	mg/L	200.8	a	
14808-79-8	SULFATE	1.6	250	10	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	78	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	0.0528	5.00	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	a	
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.4	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.4	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.4	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	a	
75-09-2	DICHLOROMETHANE	ND	3	0.4	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
16655-82-6	3-HYDROXYCARBOFURAN	ND		1.0	ug/L	531.2	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
116-06-3	ALDICARB	ND		1.0	ug/L	531.2	a	
1646-88-4	ALDICARB SULFONE	ND		1.6	ug/L	531.2	a	
1646-87-3	ALDICARB SULFOXIDE	ND		1.0	ug/L	531.2	a	
309-00-2	ALDRIN	ND		0.1	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
23184-66-9	BUTACHLOR	ND		0.1	ug/L	525.2	a	
63-25-2	CARBARYL	ND		1.0	ug/L	531.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
117-81-7	DI(ETHYLHEXYL)-PHTHALATE	ND	6	0.6	ug/L	525.2	a	
103-23-1	DI(ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
96-12-8	1,2-DIBROMO-3-CHLOROPROPANE (DI	ND	0.2	0.02	ug/L	504.1	a	
1918-00-9	DICAMBA	ND		0.2	ug/L	515.4	a	
60-57-1	DIELDRIN	ND		0.1	ug/L	525.2	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
1746-01-6	DIOXIN (2,3,7,8-TETRACHLORODIBEN;	ND	30	5	pg/L	1613		Analyzed by PACE_MN
85-00-7	DIQUAT	ND	20	0.4	ug/L	549.2	a	
145-73-3	ENDOTHALL	ND	100	9	ug/L	548.1	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
1071-83-6	GLYPHOSATE	ND	700	6	ug/L	547	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
16752-77-5	METHOMYL	ND		1.0	ug/L	531.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
51218-45-2	METOLACHLOR	ND		0.1	ug/L	525.2	a	
21087-64-9	METRIBUZIN	ND		0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB	ND	0.5	0.5	ug/L	508.1	a	
1918-16-7	PROPACHLOR	ND		0.1	ug/L	525.2	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
E-10253	TOTAL PHENOLIC COMPOUNDS	ND	1	1	ug/L	420.4		Analyzed by NSF

## Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Perfluorinated Compounds

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
-	N-ETHYL PERFLUOROOCTANESULFOI	ND			ug/L	537		
-	N-METHYL PERFLUOROOCTANESULF	ND			ug/L	537		
375-73-5	PERFLUOROBUTANESULFONIC ACID I	ND		0.09	ug/L	537		
335-76-2	PERFLUORODECANOIC AICD (PFDA)	ND			ug/L	537		
307-55-1	PERFLUORODODECANOIC AICD (PFD	ND			ug/L	537		
375-85-9	PERFLUOROHEPTANOIC ACID (PFHPA	ND		0.01	ug/L	537		
355-46-4	PERFLUOROHEXANESULFONIC ACID	ND		0.03	ug/L	537		
307-24-4	PERFLUOROHEXANOIC ACID (PFHxA)	ND			ug/L	537		
375-95-1	PERFLUORONONANOIC ACID (PFNA)	ND		0.02	ug/L	537		
1763-23-1	PERFLUOROOCTANESULFONIC ACID	ND		0.04	ug/L	537		
335-67-1	PERFLUOROOCTANOIC ACID (PFOA)	ND		0.02	ug/L	537		
376-06-7	PERFLUOROTETRADECANOIC AICD (F	ND			ug/L	537		
72629-94-8	PERFLUOROTRIDECANOIC AICD (PFTI	ND			ug/L	537		
2058-94-8	PERFLUOROUNDECANOIC AICD (PFU	ND			ug/L	537		

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1332-21-4	ASBESTOS	ND	7	0.098	MFL>10urn	100.2		Analyzed by EMSL
E-10139	HYDROGEN ION (pH)	6.49			pH Units	150.1	a	Temp (C) : 23.2
NA	TASTE	ND		1		SM2160 B	a	
NA	MBAS (Surfactants)	ND			mg/L	SM5540 C		Analyzed By NSF
E-11712	COLOR	ND	15	5	COLOR UI	SM2120 B	a	pH:6.5
E-11734	ODOR	ND	3	1	TON	SM2150	a	Temperature: 40.9
E-10617	TURBIDITY	0.45	1	0.10	NTU	180.1	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
7758-19-2	CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
NA	HAA(5)	ND	60	2	ug/L	552.3	a	
79-43-6	DICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
76-03-9	TRICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
631-64-1	DIBROMOACETIC ACID	ND		1	ug/L	552.3	a	
79-11-8	MONOCHLOROACETIC ACID	ND		2	ug/L	552.3	a	
79-08-3	MONOBROMOACETIC ACID	ND		1	ug/L	552.3	a	
E-14471	TOTAL TRIHALOMETHANE	ND	10	0.4	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	0	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50	0	pCi/L	900.0		
13982-63-3	RADIUM 226	ND			pCi/L	903.1		
15262-20-1	RADIUM 228	ND	5	5	pCi/L	904.0		
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	
14859-67-7	RADON	<b>1100</b>			pCi/L	SM7500-Rn B		Analyzed by EEA IN

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .



## BOTTLED WATER STANDARD OF QUALITY REPORT

### Additional Volatile Organic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
542-75-6	1,3-DICHLOROPROPYLENE, TOTAL	ND		0.5	ug/L	524.2	a	
75-34-3	1,1 - DICHLOROETHANE	ND		0.5	ug/L	524.2	a	
563-58-6	1,1 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
630-20-6	1,1,1,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
79-34-5	1,1,2,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
87-61-6	1,2,3 - TRICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
96-18-4	1,2,3 - TRICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
95-63-6	1,2,4 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
142-28-9	1,3 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-67-8	1,3,5 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
594-20-7	2,2 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-86-1	BROMOBENZENE	ND		0.5	ug/L	524.2	a	
74-97-5	BROMOCHLOROMETHANE	ND		0.5	ug/L	524.2	a	
74-83-9	BROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-00-3	CHLOROETHANE	ND		0.5	ug/L	524.2	a	
74-87-3	CHLOROMETHANE	ND		0.5	ug/L	524.2	a	
10061-01-5	CIS - 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
74-95-3	DIBROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-71-8	DICHLORODIFLUOROMETHANE	ND		0.5	ug/L	524.2	a	
87-68-3	HEXACHLOROBUTADIENE	ND		0.5	ug/L	524.2	a	
98-82-8	ISOPROPYLBENZENE	ND		0.5	ug/L	524.2	a	
541-73-1	M - DICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
1330-20-7	M/P - XYLENE	ND		0.5	ug/L	524.2	a	
1634-04-4	METHYL TERT-BUTYL ETHER	ND		0.5	ug/L	524.2	a	
104-51-8	N - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
103-65-1	N - PROPYLBENZENE	ND		0.5	ug/L	524.2	a	
91-20-3	NAPHTHALENE	ND	14	0.5	ug/L	524.2	a	
95-49-8	O - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
106-43-4	P - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
95-47-6	O - XYLENE	ND		0.5	ug/L	524.2	a	
99-87-6	P - ISOPROPYLTOLUENE	ND		0.5	ug/L	524.2	a	
135-98-8	SEC - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
98-06-6	TERT - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
10061-02-6	TRANS- 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
75-69-4	TRICHLOROFLUOROMETHANE	ND		0.5	ug/L	524.2	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Additional Inorganic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-11778	HARDNESS	<b>24.5</b>		10	mg CaCO <sub>3</sub>	200.7	a	
E-14506	ALKALINITY	<b>37.9</b>		1	mg CaCO <sub>3</sub>	SM2320 B	a	
NA	CORROSIVITY	<b>-2.84</b>			SI	SM203	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
 MRL - Method Reporting Limit .

**BOTTLED WATER STANDARD OF QUALITY REPORT****Inorganic Chemicals (Massachusetts)**

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1497-73-0	PERCHLORATE	ND	0.002	0.001	mg/L	331.0		Analyzed by Eurofins Eaton - Monro

## Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
MRL - Method Reporting Limit .



Burlington, WA *Corporate Laboratory (a)*  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA *Microbiology (b)*  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*  
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR *Microbiology/Chemistry (d)*  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR *Microbiology (e)*  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

# Data Report

Client Name: Idaho Ice  
 220 W. Morton St.  
 Moscow, ID 83843

Reference Number: **19-42493**  
 Project: 50 State Source Testing

Report Date: 1/6/20

Date Received: 11/6/19

Approved by: ajw,bj

Authorized by:

  
 Patrick Miller, MS  
 QA Officer

Sample Description: Source									Sample Date: 11/5/19 5:30 pm			
Lab Number: 82175		Sample Comment:							Collected By: Jim Schwartz			
Sample Type: Grab												
CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	6.5	0.5	0.009	mg/L	1.0	200.7	a	11/11/19	BJ	200.7_191111A	
7439-95-4	MAGNESIUM	2.0	0.5	0.001	mg/L	1.0	200.7	a	11/11/19	BJ	200.7_191111A	
7440-09-7	POTASSIUM	ND	1.0	0.1	mg/L	1.0	200.7	a	11/11/19	BJ	200.7_191111A	
7440-23-5	SODIUM	7.1	0.5	0.05	mg/L	1.0	200.7	a	11/11/19	BJ	200.7_191111A	
24959-67-9	BROMIDE	0.006	0.005	0.00054	mg/L	1.0	300.1	a	11/12/19	BJ	300.1_191111A	
E-10184	ELECTRICAL CONDUCTIVITY	78.5	10		uS/cm	1.0	SM2510 B	a	11/6/19	BSP	EC_191106	
	TOTAL COLIFORM For Taste Test	A	P/A		per 100mL	1.0	SM9223 B/Colilert-18	a	11/7/19	AJW	M_191106BUR	

**Notes:**

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.  
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.  
 D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.